

Mimik Novo Passive 15 - Supervisione dettagliata in base alla $T_{si\ min}$

		PARETE 01			PARETE 02			PARETE 03			PARETE 04			PARETE 05		
		superiore	laterale	inferiore	superiore	laterale	inferiore	superiore	laterale	inferiore	superiore	laterale	inferiore	superiore	laterale	inferiore
-15°C Selva Val Gardena	Uf=0,85	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
	Uf=1,10	OK	OK	OK	OK	OK	VAL	OK	OK	OK	OK	OK	VAL	OK	OK	VAL
	Uf=1,40															
-10°C Vipiteno	Uf=0,85	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
	Uf=1,10	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
	Uf=1,40															
-5°C Verona	Uf=0,85	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
	Uf=1,10	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
	Uf=1,40	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
0°C Roma	Uf=0,85	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
	Uf=1,10	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
	Uf=1,40	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
+5°C Palermo	Uf=0,85	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
	Uf=1,10	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
	Uf=1,40	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK	OK
fRsi	Uf=0,85	0,89	0,86	0,86	0,88	0,89	0,88	0,87	0,9	0,84	0,88	0,89	0,84	0,88	0,91	0,88
	Uf=1,10	0,89	0,86	0,86	0,87	0,88	0,83	0,87	0,9	0,84	0,88	0,89	0,83	0,88	0,9	0,83
	Uf=1,40	0,88	0,86	0,85	0,87	0,88	0,85	0,87	0,89	0,84	0,88	0,89	0,79	0,88	0,9	0,78

OK Componente adeguato alla T_e di riferimento.

VAL Riferito alla T_e : componente che necessita di alcune valutazioni aggiuntive.

NO Componente non adeguato alla T_e di riferimento.



PHI Italia Soc. Coop.
Via Parma, 76/6
I-39100 Bolzano (BZ)

Web: www.phi-italia.it
Email: info@phi-italia.it

2015-03-01 sb Abacolmb - Mimik Novo 15.odt
Samuel Buraschi
Pagina 10 di 18